

20

# INTERSPIRO

December 23, 1987

Director  
Division of Safety Research  
NIOSH  
944 Chestnut Ridge Road  
Morgantown, WV 26505

RE: 42 CFR Part 84, Notice of proposed rulemaking


Dear Sir:

Interspiro is pleased to submit the enclosed comments and recommendations to the Notice mentioned above.

If you have any questions or need further information, please do not hesitate to contact us.

Please inform us as to the time and place of the public hearings in this matter.

Sincerely,



Hans O. Almqvist  
President

HOA:jh  
enclosures

VIA FEDERAL EXPRESS

RECEIVED  
1987 DEC 31 PM 12:12  
NIOSH

*Copy of  
Fed Reg Sent  
Vol 52, No. 195  
12.31.87*

### Respirator Testing

Ref. Subpart D, Sections 84.30 through 84.34

Comment: Regarding the "workplace or simulated workplace testing", we conclude that:

- this test is expensive, which will add considerably to the cost of the respirator;
- it is unclear if a respirator intended for the fire service and hazardous materials handling shall be tested in a mine or an environment more related to fire department and industrial use;
- the guidelines leave open many alternative interpretations regarding test conditions and test performance.

Recommendation: The standard should include more specific rules as regards "workplace conditions" and referrals to a manufacturer-independent laboratory with appropriate testing facilities; preferably, a non-profit organization operating in the public interest.

Minor Subjects

## Section 84.11(d)

It seems to us that a minimum of four respirators would be needed, should NIOSH decide to perform its own tests (Section 84.248-12-13).

## Section 84.220(i)

The term "resistant" may have to be defined more explicitly.

## Section 84.232(e)

The stated 10% linearity requirement on the aerosol detector is probably very difficult to achieve when respirators are tested for the highest protection factors. Some advice regarding alternative measuring procedures would be of considerable value to manufacturers.

## Section 84.240(a)

"Enriched air" could possibly be added as part of the breathing gases.

## Section 84.244(g)

The rule for determining the maximum escape of air for open-circuit respirators is unclear to us. A possible solution would be to specify a maximum leakage in liters per minute when measured at 25 percent of the service pressure.

## Section 84.248-3(c)

The reference should be made to footnote 3 rather than footnote 1.


## Section 84.248-7(a) (4)

The reference to paragraph (e) is not clear to us.


Section 84.248.17(e) and (f)

We feel that the tightness test using negative pressure is inadequate for any full facepiece intended for use with a positive pressure regulator. In this case, the seal should prevent major escape of breathing gas to the surroundings, which cannot be demonstrated by a negative pressure test.

We suggest that a visual inspection of the sealing surface before and after the flame test should be considered sufficient for positive pressure types of respirators.




Spirograph test-sheet






# Spirograph test-sheet





Spirograph test-sheet






IS V




# Spirograph test-sheet



100 200 300 400

100 200 300 400




## Dead space measurements

Filename: XXXXXXXXXX  
 Samples : 84 - 340  
 Date : 1986-JAN-16  
 Test number : 1  
 Gas mixture : Air  
 Depth : Atmospheric pressure  
 Test conditions : 10.5 l/min  
 The CO<sub>2</sub>-signal was delayed 16 samples

Unit A  
 10.5 l/min

kPa CO<sub>2</sub>, 0.5 kPa per division



Volume, 0.1 litre per division

## Calculations :

Tidal volume .7 l ATP  
 Endtidal CO<sub>2</sub> 5.2 kPa (= 5.2 %)  
 Inspired volume of CO<sub>2</sub> 9.7 ml ATP  
 Average inspired CO<sub>2</sub> 1.4 kPa (= 1.4 %)  
 External dead space .19 l ATP

**AUT**

Advanced Underwater Technology AB  
 Göteborg, Sweden

15 VIII

Dead space measurements

Filename: ~~XXXXXXXXXX~~  
Samples : 29 - 228  
Date : 1985-OCT-09 10.56.28  
Test number : 2  
Gas mixture : Air  
Depth : Atmospheric pressure  
Test conditions : ~~XXXXXXXXXX~~ 20±2.0  
The CO<sub>2</sub>-signal was delayed 13 samples

Unit A  
40 l/min

kPa CO<sub>2</sub>, 0.5 kPa per division



Volume, 0.1 litre per division

Calculations :

Tidal volume 2 l ATP  
Endtidal CO<sub>2</sub> 5.1 kPa  
Inspired volume of CO<sub>2</sub> 10.6 ml ATP  
Average inspired CO<sub>2</sub> .53 kPa  
External dead space .21 l ATP

**AUT**

Advanced Underwater Technology AB  
Göteborg, Sweden


IS IX

Unit B

10.5 l/min

Filename: [REDACTED]  
Samples : 600 - 850  
Date : 1986-JAN-17  
Test number : 17  
Gas mixture : Air  
Depth : Atmospheric pressure  
Test conditions : [REDACTED]  
The CO<sub>2</sub>-signal was delayed 16 samples

kPa CO<sub>2</sub>, 0.5 kPa per division



Volume, 0.1 litre per division

Calculations :

Tidal volume .7 l ATP  
Endtidal CO<sub>2</sub> 5.1 kPa (= 5.1 %)  
Inspired volume of CO<sub>2</sub> 11.8 ml ATP  
Average inspired CO<sub>2</sub> 1.7 kPa (= 1.7 %)  
External dead space .23 l ATP

**AUT**

Advanced Underwater Technology AB  
Göteborg, Sweden


IS X

### Dead space measurements

Filename: [REDACTED]  
Samples : 255 - 450  
Date : 1985-07-09 18.39.16  
Test number : 20  
Gas mixture : Air  
Depth : Atmospheric pressure  
Test conditions : [REDACTED] 20x2.0  
The CO<sub>2</sub>-signal was delayed 13 samples

Unit B  
46 l/min

kPa CO<sub>2</sub>: 0.8 kPa per division




Volume, 0.1 litre per division

#### Calculations :

Tidal volume 2 l ATP  
Endtidal CO<sub>2</sub> 5.8 kPa  
Inspired volume of CO<sub>2</sub> 29 ml ATP  
Average inspired CO<sub>2</sub> 1.47 kPa  
External dead space .5 l ATP

AT

Advanced Underwater Technology AB  
Goteborg, Sweden



Sources: Respiration and Circulation  
 Ed.: P.L. Altman and D.S. Dittmer  
 Fed. of Am Soc for Experimental Biology  
 Bethesda Md 1971

C. Malmsten, Mats Rosander  
 Rök- och kemdykning  
 Sv. Brandförsvarsfören 1987